Hygiene-Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Director: Dr. Thomas-Benjamin Seiler
Legal Entity: Verein des Hygiene-Instituts des Ruhrgebiets e.V.

Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthauser Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Internet www.hyg.de

Our reference: W-417939e-26-Zd
Contact person: B. Zeidler

Gelsenkirchen, 18.08.2026

Test - certificate

hygiene–conformity check to the design requirements of selected regulations

Test institute:	Hygiene Institut des Ruhrgebiets Institut für Umwelthygiene und Toxikologie Rotthauser Straße 21 45879 Gelsenkirchen
Test object:	heat exchanger of the types RRT-P, RRS-P, RRU-P, RRC-P, RRV-P, RRA-P RRT-E, RRS-E, RRU-E, RRC-E, RRV-E, RRA-E RRT-N, RRS-N, RRU-N, RRC-N, RRV-N, RRA-N RRT-K, RRS-K, RRU-K, RRC-K, RRV-K, RRA-K
Manufacturer:	Klingenburg GmbH Brüsseler Str. 77 45968 Gladbeck
Basis of the examination:	✓ VDI 6022, sheet 1 (01/2018) ✓ VDI 3803, page 1 (05/2020) ✓ ÖNORM H 6020 (03/2024) ✓ ÖNORM H 6021 (01/2023) ✓ SWKI VA104-01 (01/2019) ✓ SWKI VA105-01 (08/2015)
Validity period:	5 years 08/2026 – 08/2031
Test report:	W-417935-26-Zd, W-417936-26-Zd, W-417937-26-Zd, W-417938-26-Zd

In conclusion it can be stated that the examined heat exchangers, as specified in the test report W-417935-26-Zd, W-417936-26-Zd, W-417937-26-Zd and W-417938-26-Zd, is in compliance with the above mentioned regulations.

(B. Zeidler)
clerk of the Department hygienic building technology

(J. Rolle B. Eng.)
clerk of the Department hygienic building technology

issued 18.08.2026, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentions regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.